

DECEMBER 2016 OUTAGE SUMARY

Date	Duration (Min)	Number of Customers Affected	RUS Cause Code	Cause of Service Interruption (RUS Designation 1730A-119)	Substation	OH/ URD	Customer Minutes of Interruption
12/09/16	100	1	500	Overloaded transformer	Absarokee	OH	100
12/10/16	210	9	300	Bad elbow	Nye	URD	1890
12/11/16	120	1	300	Phase connectors	Luther	OH	120
12/11/16	100	25	unknown	Open OCR	Absarokee	OH	2500
12/12/16	10	7	300	Bad elbow	Nye	OH	70
12/16/16	225	15	300	Broken wire	Edg/From	OH	3375
12/18/16	225	15	300	Broken conductor	Nye	OH	225
12/23/16	15	50	other	BEC dig in on our primary	Red Lodge	URD	750
12/27/16	120	1	300	Broken jumper	Columbus	OH	120
TOTALS	1125	124					9150

RUS CAUSE CODE KEY	
[000]	Power Supplier
[090]	Weather
[110]	Planned Outage/Maintenance
[300]	Other Material/Equipment
[490]	Trees
[500]	Transformer
[690]	Animals
[790]	Public Caused
	All Other/Unknown

Absarokee	2
Belfry	0
Columbus	1
E Rosebud	0
Edg/From	1
Luther	1
Nye	3
Red Lodge	1
Reed Pnt	0
Roberts	0