

JANUARY 2017 OUTAGE SUMMARY

Date	Duration (Min)	Number of Customers Affected	RUS Cause Code	Cause of Service Interruption (RUS Designation 1730A-119)	Substation	OH/ URD	Customer Minutes of Interruption
01/04/17	180	5	500	Faulty transformer	Roberts	OH	900
01/07/17	90	4	unknown	Two blown fuses	Belfry	OH	360
01/09/17	75	1	500	Tripped transformer	Reed Point	OH	75
01/12/17	180	4	300	Broken jumper	Columbus	OH	720
01/16/17	100	1	unknown	Blown fuse	Belfry	OH	100
01/19/17	40	1	300	Over loaded transformer	Luther	OH	40
01/21/17	120	3	690	Blown fuse	Belfry	OH	360
01/23/17	120	3	unknown	Fuse open	Nye	OH	360
01/24/17	60	80	790	Snow blower discharge hit regulator	Edg/From	OH	4800
01/24/17	30	7	unknown	Blown fuse	Edg/From	OH	30
01/27/17	120	115	090	Wind broke line side jumper on OCR	Reed Point	OH/URD	13800
TOTALS	1115	224					21545

RUS CAUSE CODE KEY	
[000]	Power Supplier
[090]	Weather
[110]	Planned Outage/Maintenance
[300]	Other Material/Equipment
[490]	Trees
[500]	Transformer
[690]	Animals
[790]	Public Caused
	All Other/Unknown

Absarokee	0
Belfry	3
Columbus	1
E Rosebud	0
Edg/From	2
Luther	1
Nye	1
Red Lodge	0
Reed Pnt	2
Roberts	1