

MARCH 2017 OUTAGE SUMMARY

Date	Duration (Min)	Number of Customers Affected	RUS Cause Code	Cause of Service Interruption (RUS Designation 1730A-119)	Substation	OH/ URD	Customer Minutes of Interruption
03/01/17	60	4	300	Cutout fuse link pulled apart	Red Lodge	OH	240
03/01/17	165	1	500	Bad transformer	Columbus	OH	165
03/01/17	75	3	690	Raccoon on transformer	Columbus	OH	225
03/06/17	165	11	300	Faulted URD cable	Red Lodge	URD	1815
03/08/17	30	1	unknown	Re-fused cutout	Roberts	OH	30
03/09/17	100	3	090	Snow loading	Columbus	OH	300
03/09/17	95	47	090	Snow loading	Columbus	OH	4465
03/12/17	60	14	490	Trees on line	Roberts	OH	840
03/15/17	90	1	790	Consumer dig in	Nye	URD	90
03/16/17	60	1	490	Trees on line	Reed Point	OH	60
03/16/17	150	2	690	Cattle rubbing A-4	Columbus	OH	300
03/27/17	120	1	unknown	Blown fuse	Columbus	OH	120
03/28/17	130	3	690	Raccoon on cross arm	Edg/From	OH	390
03/30/17	60	2	unknown	Broken secondary jumper	E Rosebud	OH	120
TOTALS	1360	94					9160

RUS CAUSE CODE KEY	
[000]	Power Supplier
[090]	Weather
[110]	Planned Outage/Maintenance
[300]	Other Material/Equipment
[490]	Trees
[500]	Transformer
[690]	Animals
[790]	Public Caused
	All Other/Unknown

Absarokee	0
Belfry	0
Columbus	6
E Rosebud	1
Edg/From	1
Luther	0
Nye	1
Red Lodge	2
Reed Pnt	1
Roberts	2